GUAM POWER AUTHORITY

ATURIDÅT ILEKTRESEDÅT GUAHAN
P.O.BOX 2977 • AGANA, GUAM U.S.A. 96932-2977

November 29, 2016

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-008-17

FOR

REMOVAL OF 30-TON CHILLER UNIT AND REPLACE WITH 30-TON DIRECT EXPANSION COOLING UNIT AT OUR GPA POWER SYSTEMS CONTROL CENTER, PITI

Prospective Bidders are hereby notified of the following response to inquiries received from JWS Refrigeration & Air Conditioning, Ltd. dated November 23, 2016 and Polyphase System, Inc. dated November 23, 2016:

JWS Refrigeration & A/C:

QUESTION:

1. Extend the bid date from November 30, 2016 to December 7, 2016.

ANSWER:

Bid Opening date is changed from 2:00 P.M., November 30, 2016 to now read 2:30 P.M., December 07, 2016.

QUESTION:

2. Delivery 10 weeks ARO to 16 Weeks ARO.

ANSWER:

Delivery date is changed from 10 Weeks ARO to now read 24 Weeks ARO.

QUESTION:

3. Confirm AHU/ACCU to be removed and replace (AHU-4/ACCU-4 OR AHU-5/ACCU-5).

ANSWER:

There is no preference as they both will be coming out.

Polyphase System Inc.:
Please clarify on the following concerns as listed below:

QUESTION:
1. Coated Copper tubes to copper fins for the Condenser coil.

ANSWER:
The condenser fins shall be coated.

QUESTION:
2. Request for bid extension for one (1) week in order for us to get competitive price for the Chiller & Air Handler Unit.

ANSWER:
Bid Opening date is changed from 2:00 P.M., November 30, 2016 to now read 2:30 P.M. December 07, 2016.

QUESTION:
3.0 Delivery and Installation be revised to 16 weeks ARO due to the Special requirement for the condenser coil.

I'm sorry I have to make correction for Item 3.0 below. Just received quotation today from "Trane" and the production time of the Chiller & AHU is 13 weeks plus 3-4 weeks shipping time to Guam upon receipt of approved submittals. Based on this delivery time, we hereby request for Delivery and installation period of 24 weeks ARO.

ANSWER:
Delivery date is changed is changed from 10 Weeks ARO to now read 24 Weeks ARO.

QUESTION:
4. There are two Air Handler Units installed on site. Please confirm if only 1 each Air Handling Unit is to be replaced.

ANSWER:
Only one AHU will be removed. The AHU associated with the chiller shall be removed.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

JOHN M. BENAVENTE, P.E.
General Manager