



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

January 21, 2020

AMENDMENT NO.: II

TO

INVITATION FOR BID NO.: GPA-020-20

FOR

PAD MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following change and clarification to Amendment No.: I response to inquiry received from America's Best Electricmart, Inc. dated 01/07/20 and Benson Guam Ent, Inc. inquiry dated 01/21/20:

CHANGE:

Bid Opening Date is changed *FROM* 2:30 P.M., Tuesday, January 21, 2020 *TO NOW READ* 2:00 P.M., Tuesday, January 28, 2020.

CLARIFICATION RESPONSE to America's Best Electricmart, Inc. inquiry:

QUESTION:

1. I have a question regarding section 9.6 of specification E-004. This section indicates that the transformer top needs to be convex or constructed so that water will run off the top. Is this still a requirement? I've seen recent transformers purchased by GPA that seem to be flat on top.

ANSWER:

Yes. Kindly refer to GPA Specification E-003 and E-004, Section 9.

Benson Guam Ent., Inc. inquiry dated 01/21/20:

QUESTION:


1. I'm confused by the latest amendment. It sounds like the responder thought this inquiry be ABE is for pole mounted transformers, when in fact this is a bid for pad mounted.

Is that correct?

ANSWER:

Kindly refer to **CLARIFICATION RESPONSE** above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



JOHN M. BENAVENTE, P.E.
General Manager

