



# GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN  
P.O.BOX 2977 • AGANA, GUAM U.S.A. 96932-2977

March 12, 2018

**AMENDMENT NO.: V**

**TO**

**INVITATION FOR BID NO.: GPA-037-18**

**FOR**

**STANDBY GENERATORS**

Prospective Bidders are hereby notified of the following response to clarification received from Far East Equipment Company, LLC dated March 09, 2018:

**Far East Equipment Company LLC clarification to Amendment No.: IV:**

**QUESTION:**

1. Regarding Amendment No.: IV [GPA response to Question 1].

**B.11 Mainline Circuit Breaker 140 minimum 175 maximum amp mounted-thermal magnetic trip type.**

Question: The standard MLCB in our generator is 200 AMPS, will this be acceptable?

**ANSWER:**

No. The maximum amp is 175 as indicated Under Section B. FEATURES, B.11.  
(Refer to Page Page 3c of 20, Amendment No.: IV).

All other Terms and Conditions in the bid package shall remain unchanged and in full force.

  
JOHN M. BENAVENTE, P.E.  
General Manager

*mm*