



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

July 17, 2020

AMENDMENT NO.: I
TO
INVITATION FOR BID NO.: GPA-048-20
FOR
AIR-CONDITIONING UNITS, VARIOUS SIZES (NEW)

Prospective Bidders are hereby notified of the following Inclusion and response to an inquiries received from Bidder No.: 2 dated July 16, 2020 and Bidder No.: 3 dated July 17, 2020:

To ensure the safety and well-being of personnel and prospective bidders, please be advised of the following:

1. Six (6) Feet of Social Distancing shall be practiced.
2. Mandatory face mask required for each individual.
3. Temperature checks shall be conducted upon entrance of the Gloria B. Nelson Public Service Building.
4. One (1) Personnel per Prospective Bidder to submit and attend public opening.

INCLUSION:

1. Last Day for Inquires: Wednesday, July 22, 2020 at 5:00 P.M.

Bidder No. 2 dated July 16, 2020:

QUESTION:

1. Bid is just for supply of AC and not installation?

ANSWER:

No, installation needed.

QUESTION:

2. 3 ton cooling unit – is this wall mount split type?

ANSWER:

No. This is a split ducted system. AHU unit and Compressor unit are separated.

Bidder No. 3 dated July 17, 2020:

QUESTION:

1. Is it split ducted, mini-split or package ducted?

ANSWER:

This is a split ducted system. AHU unit and Condensing unit are separated.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



for JOHN M. BENAVENTE, P.E.
General Manager