



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

July 27, 2020

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-056-20

FOR

GROUP OPERATED DISCONNECT SWITCH SET (NEW)

Prospective Bidders are hereby notified of the following change to inquiry received from Bidder No.: 1 dated July 23, 2020:

CHANGES:

1. **REMOVE** Page 2 & 4 of 20 and **REPLACE** with 2a & 4a of 20 (See attached).
 - a. On Page 2 of 20, under REQUIRED DELIVERY DATE: **FROM** 16 Weeks After Receipt of Order (ARO) **TO NOW READ** 32 Weeks After Receipt of Order (ARO)
 - b. On Page 4 of 20, under Delivery Requirement: **FROM** 16 Weeks After Receipt of Order (ARO) **TO NOW READ** 32 Weeks After Receipt of Order (ARO)
 - c. On Page 4 of 20, under **TO BE COMPLETED BY BIDDER:**, verbiage is changed

FROM:

MANUFACTURED BY/BRAND NAME:

MANUFACTURED BY/BRAND NAME:

TO NOW READ:

MANUFACTURED BY/BRAND NAME:

CAT. NO. / MODEL NO.:

Bidder No.: 1 dated 07/23/2020:

QUESTION:

1. As per manufacturer, the current delivery schedule for this Disconnect Switch is 26 to 28 weeks ex-factory plus 10 days inland trucking to West Coast please 14 days ocean shipping time to Guam.


In this regards, we would like to request for an amendment to amend the delivery date to 28 to 32 weeks.

ANSWER:

Kindly refer to #1 a. & b. of **CHANGES** above.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



for JOHN M. BENAVENTE, P.E.
 General Manager

INVITATION FOR BID

ISSUING OFFICE:

Guam Power Authority
Procurement Management Materials Supply
Gloria B. Nelson Public Service Building
688 Route 15, Mangilao, Guam 96913

7/28/2020

FOR **JOHN M. BENAVENTE, P.E.** DATE
 General Manager

DATE ISSUED: 07/21/2020
07/14/2020 BID INVITATION NO.: GPA-056-20

BID FOR: Group Operated Disconnect Switch Set (New)

SPECIFICATION: See Attached

DESTINATION: Guam Power Authority, Dededo Warehouse

**** REQUIRED DELIVERY DATE: 32 Weeks After Receipt of Order (ARO)**

INSTRUCTIONS TO BIDDERS:

INDICATE WHETHER: INDIVIDUAL PARTNERSHIP CORPORATION

INCORPORATED IN: _____

This bid shall be submitted in duplicate and sealed to the issuing office above no later than (Time) 2:30 P.M.,
Date: 07/29/2020 and shall be publicly opened. Bid submitted after the time and date specified above shall
be rejected. See attached General Terms and Conditions and Sealed Bid Solicitation for details.

The undersigned offers and agrees to furnish within the time specified, the articles and services at the price stated opposite
the respective items listed on the schedule provided, unless otherwise specified by the bidder. In consideration to the
expense of the Government in opening, tabulating, and evaluating this and other bids, and other considerations, the
undersigned agrees that this bid remain firm and irrevocable within one hundred twenty (120) calendar days from the date
opening to supply any or all of the items which prices are quoted.

NAME AND ADDRESS OF BIDDER:

SIGNATURE AND TITLE OF PERSON
AUTHORIZED TO SIGN THIS BID:

AWARD: CONTRACT NO.: _____ AMOUNT: _____ DATE: _____

ITEM NO(S). AWARDED: _____

CONTRACTING OFFICER:

JOHN M. BENAVENTE, P.E. DATE
General Manager

NAME AND ADDRESS OF CONTRACTOR:

SIGNATURE AND TITLE OF PERSON

INVITATION FOR BID NO.: GPA-056-20
REQUISITION NO.: 33977

NO.	DESCRIPTION	QTY	U/I	U/P:	T/P
1.0	Group Operated Disconnect Switch Set (New)	3	SE	\$ _____	\$ _____

COMPLY / NON-COMPLIANCE

A. SPECIFICATIONS:

- A.1- Outdoor air break switch
- A.2- Type "V" center break switch
- A.3- Maximum voltage rating: 38 kV
- A.4- Nominal voltage: 34.5 kV
- A.5- BIL: 200 kV
- A.6- Rated power frequency: 60 Hz
- A.7- Continuous current: 1200 A
- A.8- Post insulators: TR-210
- A.9- Height from NEMA terminal pad to base level:
26" +/- 1"
- A.10- All copper current carrying parts
- A.11- NEMA pads are tinned
- A.12- Permanently lubricated, maintenance-free bearing
Assembly
- A.13- Rigid galvanized steel base assembly
- A.14- Set must consist of 3 each pole units and a standard
galvanized steel swing handle operator assembly

**** DELIVERY REQUIREMENT:**

32 Weeks After Receipt of Order (ARO)

NOTE:

Notwithstanding the fact that this contract was written by One (1) party, it will be construed that it was written by Two (2) parties.

TO BE COMPLETED BY BIDDER:

MANUFACTURED BY/BRAND NAME: _____

**** CAT. NO. / MODEL NO.:** _____

PLACE OF ORIGIN: _____


EXPORT ABROAD: _____

TIME OF DELIVERY AFTER RECEIPT OF PURCHASE ORDER: _____


Specifications Generated/Review By:


Vincent A. Pangelinan Date 7/27/20
T&D Power Systems Superintendent

Specifications Concurred By:


Anselmo M. Manibusan Date 7/27/2000
T&D Manager

Specifications Approved By:


Melinda C. Mafnas, P.E. Date
Assistant General Manager of Operation