



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

July 29, 2020

AMENDMENT NO.: II

TO

INVITATION FOR BID NO.: GPA-056-20

FOR

GROUP OPERATED DISCONNECT SWITCH SET (NEW)

Prospective Bidders are hereby notified of the following change and inclusion to an inquiry received from Bidder No.: 3 dated July 28, 2020:

CHANGE:

Bid Opening Date is changed **FROM** 2:30 P.M., Wednesday, July 29, 2020 (CHamoru Standard Time) **TO NOW READ** 2:30 P.M., Wednesday, August 05, 2020 (CHamoru Standard Time).

INCLUSION:

Last Day for Inquires: Thursday, July 30, 2020 at 5:00 P.M.

Bidder No. 3 dated July 28, 2020:

QUESTION:

1. Could you kindly verify with GPA if they will accept Side Break or Vertical Break style switch as an alternative to Center Break?

Looking at the specs it requires for "V" type Centre break switch for 34.5 kV, but we don't have Center Break switch.

ANSWER:

The Authority's requirement of a Type "V", center-break switch shall remain the same. A side-break or vertical-break switch is not acceptable.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.



for JOHN M. BENAVENTE, P.E.

 General Manager