



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN
P.O.BOX 2977 • AGANA, GUAM U.S.A. 96932-2977

April 10, 2018

AMENDMENT NO. I

TO

INVITATION FOR BID NO.: GPA-064-18

FOR

PAD MOUNTED TRANSFORMERS

Prospective Bidders are hereby notified of the following response to inquiries received from Benson Guam Enterprises, Inc. dated April 07, 2018:

Benson Guam Enterprises, Inc. dated 04/07/18:

QUESTION:

1. Is the primary voltage for these units:
7970/13800y (7970 is mentioned on page 3 and 4 of the attachment)
Or
13800 Delta (13800 is mention on Page 9 of the attachment)

ANSWER:

The primary voltage shall be 13800Y/7970 Volts. The transformer shall ne in accordance with E-003 with the 13800Y/7970 primary voltage.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


JOHN M. BENAVENTE, P.E.
General Manager