



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN
P.O.BOX 2977 • AGANA, GUAM U.S.A. 96932-2977

June 05, 2017

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-068-17

FOR

WIRES

Prospective Bidders are hereby notified of the following response to inquiries received from EPC International Pty Ltd dated June 05, 2017.

QUESTION:

1. On page 15, for wire #2 AWG Triplex copper 600V, self-supporting secondary cable, which standard from the below table should we refer to:

table A of page 12, Specification No. E-022 REVISION 3 there are two types like below:

2	7	45	4	7	1505	593.7	195
2	7	45	2	7	2360	669.7	195

ANSWER:

Kindly refer to Page 12 of 35 under Table A, Triplex, 5th Line. (See Attached).

All other Terms and Conditions in this bid package shall remain unchanged and in full force.


 JOHN M. BENAVENTE, P.E.
 General Manager

 GUAM POWER AUTHORITY AGANA, GUAM	SPECIFICATION No. E-022	PAGE 6 OF 6
		REVISION: 3 January 5, 2007
PREPARED BY THE ENGINEERING DEPT.		

9.0

TABLE A

PHASE CONDUCTOR			NEUTRAL-MESSENGER			WEIGHT PER 1000 FEET (Lbs.)	AMPACITY (AMPS)
Size (AWG)	Stranding	Cover Thick (MILS)	Size (AWG)	Stranding	Min. Ultimate Strength (lbs.)	VIP	VIP
DUPLEX							
8	7	45	8	7	610	115.8	84
6	7	45	6	7	959	179.1	110
TRIPLEX							
8	7	45	8	7	610	180.6	84
6	7	45	6	7	959	277.2	110
4	7	45	4	7	1505	429.6	145
2	7	45	4	7	1505	593.7	195
2	7	45	2	7	2360	669.7	195
1/0	19	60	1/0	7	3705	1070.6	260
2/0	19	60	2/0	7	4765	1338.7	300
4/0	19	60	4/0	7	7479	2099.4	395
QUADRUPLEX							
6	7	45	6	7	959	375.3	95
4	7	45	4	7	1505	580.0	125
2	7	45	2	7	2360	902.3	165
1/0	19	60	1/0	7	3705	1443.1	225
2/0	19	60	2/0	7	4765	1802.7	260

EFFECTIVE DATE: 1/5/07 ISSUED: *[Signature]* APPROVED: *[Signature]*