



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUAHAN
P.O.BOX 2977 • AGANA, GUAM U.S.A. 96932-2977

May 08, 2018

AMENDMENT NO.: I

TO

INVITATION FOR BID NO.: GPA-072-18

FOR

RELAY TEST EQUIPMENT

Prospective Bidders are hereby notified of the following response to inquiry received from America's Best ElectricMart dated May 04, 2018:

QUESTION:

1. The manufacturer we represent for this type of equipment (item #1 of GPA-072-18) is asking how many simultaneous voltage and simultaneous current channels are needed for GPA's applications?

ANSWER:

Requirement is for 6 current sources and 4 voltage sources simultaneously and must be compatible with CMC test universe software.

6x 32A/430VA
3X 64A/860VA
1X 128A/ 1000VA
4X 300V

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


JOHN M. BENAVENTE, P.E.
General Manager