



GUAM POWER AUTHORITY

ATURIDÁT ILEKTRESEDÁT GUÅHAN
P.O.BOX 2977 • HAGÁTÑA, GUAM U.S.A. 96932-2977

June 29, 2020

AMENDMENT NO.: VI

TO

INVITATION FOR RE-BID NO.: GPA-057-19

FOR

MOBILE DIESEL STANDBY GENERATOR WITH TRAILER

Prospective Bidders are hereby notified of the following changes, response to an inquiry received from Bidder No.: 1 dated June 26, 2020:

CHANGE:

Bid Opening Date is changed **FROM** 2:30 P.M., Tuesday, June 30, 2020 (CHamoru Standard Time) **TO NOW READ** 2:30 P.M., Wednesday, July 08, 2020 (CHamoru Standard Time).

To ensure the safety and well-being of personnel and prospective bidders, please be advised of the following:

1. Six (6) Feet of Social Distancing shall be practiced.
2. Mandatory face mask required for each individual.
3. Temperature checks shall be conducted upon entrance of the Gloria B. Nelson Public Service Building.
4. One (1) Personnel per Prospective Bidder to submit and attend public opening.

Bidder No. 1 dated June 26, 2020:

QUESTION:

1. AMENDMENT V

Page 3a of 19

Voltage – 3 phase 110 /220 V, 120 /240 V, 120/208 V, 277/480 V

- Please confirm 3 phase 120/208 V and 277/480 V **ONLY** are acceptable for the generator.

ANSWER:

3 phase 120/208 V and 277/480 V is acceptable for this generator.

All other Terms and Conditions in the bid package shall remain unchanged and in full force.


for JOHN M. BENAVENTE, P.E.
General Manager 